

January 23, 2009

MADISON CONCRETE PIPE, INC.
WILLIAM J. GARDNER
3725 LEXINGTON AVE
MADISON WI 53714

Re: Description: PIPE, CONCRETE BOX
Manufacturer: MADISON CONCRETE PIPE, INC.
Product Name: PRECAST CONCRETE BOX SECTIONS
Model Number(s): 4x3, 6x3, 6x4, 6x5, 6x6, 8x4, 8x5, 8x6, 10x6 (Span in feet x Rise in feet)
Product File No: 20090023

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- The complete joint between sections of this product must be sealed by the use of a flexible butyl resin sealant that complies with ASTM Standard C990 applied to the tongue or groove joint and with plastic film and mesh reinforced mastic band that comply with ASTM Standard C877 Type II external sealing band.
- This product may be installed for the following drain use(s):
 - a. Storm sewer gravity flow
 - b. Storm conveyance piping gravity flow
 - c. Storm detention piping gravity flow

This approval supersedes the approval issued on April 20, 2004 under product file number 20040158

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040158.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov